

# केन्द्रीय खनन एवं ईंधन अनुसंधान संस्थान

(वैज्ञानिक तथा औद्योगिक अनुसंधान परिषद)  
बरवा रोड, धनबाद - 826 001, झारखण्ड, भारत



ORIGINAL COPY

## Central Institute of Mining and Fuel Research

Formerly : Central Mining Research Institute  
(Council of Scientific & Industrial Research)  
BARWA ROAD, DHANBAD-826 001, JHARKHAND, INDIA

### REGISTERED POST/COURIER SERVICE

No. CIMFR/TC/P/H2/10  
Equipment ID NO. 51A/07

Dated: 14<sup>th</sup> June, 2007  
Code No. P/P/215A/07

To  
M/S. Rotex Manufacturers & Engineers Pvt. Ltd.,  
Manpada Road, Near Bhopar Village,  
Dombivli (E) - 421 204 (Maharashtra)

**Sub:** Flameproof Testing as per IS: 2148-2004 (IEC 60079-1/2001) and weatherproof testing as per IS: 12063-1987 for IP-67 of your enclosure for **Flameproof cum Weatherproof Limit Switch housing**, in Cast Aluminium Alloy construction, designated by Model: **DNLF**, for use in Gas Groups: IIA & IIB and Zone 1 atmospheres only.

- Report on (PROTOTYPE)

Your Ref. No.: ROTEX/CMRI/IIA & IIB/01  
Nil

Dated 12-04-2007 and subsequently  
Dated 02/06/2007

Dear Sir,

Please find enclosed the **Test Report (Prototype)** of the above sample submitted by you.

Charges of **Rs. 49,498/- (Rupees Forty nine thousand Four Hundred & ninety nine only)** including applicable service charges involved towards the testing/issuing the schedule have been adjusted against the advance deposit made by you.

Kindly arrange to collect the sample within 90 days from the date of receipt of this letter failing which CIMFR would dispose off the sample by public auction without any further NOTICE to you.

Kindly acknowledge receipt.

Thanking you.

Yours faithfully,

  
(G.M. PRASAD)

HEAD OF THE DEPARTMENT  
TESTING CELL

Enc. As above.  
Proto. Test Report in triplicate.  
Copy to: 1. Head, Flame & Explosion Lab.  
2. Bill Section.

फोन-निदेशक Director  
Ph.: 0091-326-2202326/2203043

फैक्स PAX

Ph.: 0091-326-2203010/2203070/2203090/2205045/2209041

फैक्स FAX

0091-326-2201442/2202429/2204339/2203156

e-mail : dcmrips@yahoo.co.in, dcmri@csir.res.in • Website : www.cmriindia.nic.in

कार्यालय के दिन : सोमवार से शुक्रवार तक Working days : Monday to Friday

के० ख० एवं ई० अ० सं० परीक्षण प्रकोष्ठ - CIMFR TESTING CELL

केन्द्रीय खनन एवं ईंधन अनुसंधान संस्थान

(वैज्ञानिक तथा औद्योगिक अनुसंधान परिषद)



ORIGINAL COPY

## CENTRAL INSTITUTE OF MINING AND FUEL RESEARCH

Formerly Central Mining Research Institute  
(Council of Scientific & Industrial Research)

बरवा रोड, धनबाद - 826 001 (भारत) - BARWA ROAD, DHANBAD-826 001 (INDIA)

### परीक्षण प्रमाण पत्र - TEST CERTIFICATE

FORMAT NO.: (CIMFR: DQM: FLP02: F-01)  
(Flame & Explosion Laboratory)

ID NO. 51A/07

Code No. FLP/215A/2007

#### SCHEDULE: FIRST

[For association with the report of test sent (under cover of this office letter No. CIMFR/TC/P/112/07  
Dated: 28 June, 2007) to M/S. Rotex Manufacturers & Engineers Pvt. Ltd., Manpada Road, Near  
Bhopar Village, Dombivli (E) - 421 204 (Maharashtra)]

1. **Applicant:** M/S. Rotex Manufacturers & Engineers Pvt. Ltd.,  
Manpada Road, Near Bhopar Village,  
Dombivli (E) - 421 204 (Maharashtra)
2. **Manufacturer:** Same as above
3. **Title of Apparatus:** Flameproof cum Weatherproof Limit Switch housing, in Cast Aluminium Alloy construction, designated by Model: **DNLF** for use in Gas Groups: IIA & IIB and Zone 1 atmospheres only.
4. **Type of Ex Protection:** Flameproof Ex 'd'
5. **Type of Ingress Protection:** IP-67
6. **Model No:** DNLF
7. **Rating of Apparatus:** As given in Second Schedule of this Report.
8. **Temperature Class:** As given in the **TABLE # 3**.
9. **Zones and Gas Group:** Gas Groups: IIA & IIB and Zone 1 only.
10. **Standard reference:**
  - (a) As to flameproof construction: IS: 2148-2004 (IEC 60079-1/2001).
  - (b) As to general design, rating, performance & T class: IS: 13346-2004 (IEC 60079-0/2000).
  - (c) As to weatherproof construction IP-67: IS: 12065-1987.
11. **Material of construction and minimum thickness:** Cast Aluminium Alloy and 8mm minimum wall thickness











के० एच० एवं ई० ३१० एच० परीक्षा केंद्र, दिल्ली-११०००१ CIMFR TESTING CELL



ORIGINAL COPY

FORMAT NO.: (CIMFR: DQM: FLP02: F-01)  
(Flame & Explosion Laboratory)

ID NO. 51A/07

Code No. FLP/215A/2007

**Table#1:** 1kg mass of hardened steel fallen vertically on the surface of the enclosure to create impact energy for Gr. II apparatus. The impact should be done for gas group I.

**Table#2: ; IP-Protection:** Neoprene O ring rubber gasket (3.0mm thick) is provided at the end of the each joint for Weatherproof IP-67 degree of protection for each enclosure. Tests have been conducted as per IS: 12063 --1987(IEC-60529/1989) as tabulated below.

Sl.No.	Type tests	Results
1	Dust Test (First Numeral 6) Clause 7.6	No dust had entered inside the enclosure Pass
2	Water Test (Second Numeral 7) Clause 8.7	No water had entered inside the enclosure Pass

**Table#3:** The surface temperature rise classifications of the above apparatus have been determined with the following micro switch at an ambient temperature of 30°C.

1. DNLF1A1 = Microswitch - V5C010EB3D, 10Amps/250 VAC/50Hz - T6
2. DNLF11A4 = Microswitch - V7-1C17E9-201, 15Amps/250 VAC/50Hz - T6
3. DNLF1B1 = Microswitch - D43 CQ1 RA, 5Amps/250 VAC/50Hz - T6
4. DNLF11B4 = Microswitch - D45 CQ1 RA, 15Amps/250 VAC/50Hz - T6
5. DNLF2A1 = NJ-2-12-GMN, 8VDC, 3mA - T6
6. DNLF12A2 = NCB2-12GM35-NO, 24 VDC, 100mA - T6
7. DNLF42A2 = NJ4-12GM50-WO, 220VAC, 200mA, 60Hz - T6
8. DNLF12B2 = NCB2-12GM35-NO, 24 VDC, 100mA - T6
9. DNLF42B2 = NJ4-12GM50 WO, 220VAC, 200mA, 50Hz - T6
10. DNLF5A2 = Microswitch - V5C010EB3D, 10Amps/250 VAC - T6

**Table#4:** The details are given below in the B. Tests as per IS: 2148-2004.

**B. Tests as per IS: 2148-2004:**

Sl.No.	Type tests	Results ( P, F, N) / Reference
1	Pressure Test 15.1.1	Test of ability of the enclosure to withstand pressure P / As per Table # A & #B
2	Reference Pressure 15.1.2	Determination of Internal Explosion Pressure P / As per Table #A
3	Over Pressure Test 15.1.3	Determination as per Static / Dynamic P / As per Table #B
4	Non-transmission of Internal ignition 15.2	Without gaskets P / As per Table #C
5	Sealing 15.3	Stopping Box with setting compound N
6	Flame proof enclosure 15.4	Test for equipment with breathing and draining devices N

Legend: P- Pass, F - Fail, N- Not applicable





## केंद्र सं० एवं ई० अ० सं० परीक्षण प्रकोष्ठ - CIMFR TESTING CELL




NA 13/07

## TEST CERTIFICATE

ID Number: 51A/07 Code Number: FLP/215A/07  
 Test Date: 27/04/2007  
 Manufacturer Details: M/S ROTEX MANUFACTURERS & ENGINEERS PVT. LTD.  
 Manufacturer Address: DOMBIVLI (E) - 421 204 MAHARASHTRA, INDIA  
 Model / Type: MODEL - DNLF  
 Category No.: NA  
 Gas: H<sub>2</sub>+CH<sub>4</sub>  
 Gas Group: IIA IIB  
 Equipment Details: FLP/WP LIMIT SWITCH  
 Enclosure Details: SINGLE ENCLOSURE  
 Serial / Badge No.: NA  
 Peak Pressure: 4.37 Bar at 13.32 ms

## Explosion Pressure vs Time Graph



*[Signature]*  
 13/07  
 (Testing Officer)

*[Signature]*  
 (Discipline Head)



ORIGINAL COPY

FORMAT NO.: (CIMFR: DQM: E.P02: F-01)  
(Flame & Explosion Laboratory)

ID NO. 51A/07

Code No. FLP/215A/2007

**C. Tests as per IS: 4013-1967**

Type of test	Clause	Gas Mixture % in Air	Result
Test For Frictional Incendivity	9.7	21% Hydrogen	Cast Aluminium Alloy (Material of construction) is non-incendive with respect to Gas Group - IIB

**TEST EQUIPMENT USED AND THEIR CALIBRATION STATUS:**

- (i) Computer, Kistler Piezo Electric Transducer & Charge Amplifier for conducting Explosion Pressure Tests.
- (ii) Fabricated set up for Dust Protection & Water Protection Testing.

**Calibration:** Calibration was performed as per in house procedure and are within the permissible range.

**ENVIRONMENTAL CONDITION WHERE APPLICABLE:** NA

**CONCLUSION:** Flameproof cum Weatherproof Limit Switch housing, designated by Model: DNLF, in Cast Aluminum Alloy LM 6 construction under reference meets the test requirements of IS: 2148-2004 in respect of flameproofness, IS: 12063-1987 in respect of IP-67 degree of protection and IS:13346-2004 in respect of general requirements for suitable in gas group IIA & IIB and Zone 1 only.

Reported by

(B. AHIRWAL)  
SCIENTIST

Dated: 13<sup>th</sup> June, 2007  
Flame & Explosion Laboratory,  
Central Institute of Mining & Fuel Research, (CSIR-INDIA)  
(Formerly: Central Mining Research Institute)  
Barwa Road, Dhanbad -826001, Jharkhand, INDIA

Approved by

(A. K. SINGH)  
HEAD OF THE DEPARTMENT

H. O. D.  
Testing Cell