



1 **SUPPLEMENTARY EC - TYPE EXAMINATION CERTIFICATE**

2 **Equipment or Protective System Intended for use in Potentially Explosive Atmospheres  
Directive 94/9/EC**

- 3 Supplementary EC - Type Examination Certificate Number: **Baseefa09ATEX0126/1**
- 4 Equipment or Protective System: **A Type DNLF Rotary Limit Switch**
- 5 Manufacturer: **Rotex Manufacturers & Engineers Private Limited**
- 6 Address: **Manpada Road, Dombivli (East), Maharashtra, 421204, India**

- 7 This supplementary certificate extends EC – Type Examination Certificate No. **Baseefa09ATEX0126** to apply to equipment or protective systems designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.

This supplementary certificate shall be held with the original certificate.

This certificate may only be reproduced in its entirety, without any change, schedule included.


Baseefa Customer Reference No. **6254**

Project File No. **11/0581**

This certificate is granted subject to the general terms and conditions of Baseefa. It does not necessarily indicate that the equipment may be used in particular industries or circumstances.

**Baseefa**

Rockhead Business Park, Staden Lane,  
Buxton, Derbyshire SK17 9RZ  
Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601  
e-mail [info@baseefa.com](mailto:info@baseefa.com) web site [www.baseefa.com](http://www.baseefa.com)  
Baseefa is a trading name of Baseefa Ltd  
Registered in England No. 4305578. Registered address as above.

  
R S SINCLAIR  
DIRECTOR  
On behalf of  
Baseefa



13

## Schedule

14

Certificate Number Baseefa09ATEX0126/1

15

### Description of the variation to the Equipment or Protective System

#### Variation 1.1

To permit the rotary limit switch to be provided with a maximum of two microswitches, proximity sensors or reed switches limited to a maximum current of 5A per switch with a subsequent change of temperature classification to T6 and a maximum ambient temperature of 55°C.

In this configuration, the rotary limit switch is rated up to 250V a.c. 220V d.c., 5A and marked:-

Ex d IIC T6 Gb (Tamb -40°C to +55°C)

or

Ex d IIC T6 Gb (Tamb -20°C to +55°C)

16

### Report Number

Baseefa Certification Report GB/BAS/ExTR11.0208/00.

17

### Specific Conditions of Use

None.

18

### Essential Health and Safety Requirements

Compliance with the Essential Health and Safety Requirements is not affected by this variation.

19

### Drawings and Documents

Number	Sheet	Issue	Date	Description
12-60-83-316	1	00	30.08.11	Assembly - 2 Switches - Aluminium - 2 entry
12-60-83-315	1	00	30.08.11	Assembly - 2 Switches - S/Steel - 2 entry
12-60-83-317	1	00	30.08.11	Assembly - 2 Switches - Aluminium - 4 entry
12-60-83-318	1	00	30.08.11	Assembly - 2 Switches - S/Steel - 4 entry
WN-2694	1	00	30.08.11	Certification Label Details DNLF -40°C
WN-2695	1	00	30.08.11	Certification Label Details DNLF -20°C

These drawings are common to, and held with, IECEx BAS 09.0054.